



Teil / Komponente	W5A-W5U	W6A-W6M	W7A-W7I	W8A/W8G	W8B/C/D/E/H/I	W8J	W11A/B/E/F	W11C-W11D	EDV
Luftkühler	Luftkühler	Luftkühler	Luftkühler	Luftkühler	Luftkühler	Luftkühler	Luftkühler	Luftkühler	Luftkühler
Alfa Laval	Alfa Laval	Alfa Laval	Alfa Laval	Alfa Laval	Alfa Laval	Alfa Laval	Alfa Laval	Alfa Laval	Carrier
BFWMH404CD	I18S553GT	BFWMH404CD	GGHF 031.2H/47	TBLH67BS	GGHF 031.2H/37	BLH252BS	BLH403CS	H-42NZS55F-H-A	
19	33	19	6.5	15	3.5	4	16	6.35	
OO in kW				0.6	0.6	0.3	0.6	0.165	
Luft ein / Luft aus °C	+4/+1.3	+4/+1	+4/+1.3	+5/+2.5	+20/+16.6	+4/+2.1	-20/-23.3	-24/-28.5	+27/+19
Eth.glykol 15%	Eth.glykol 15%	Eth.glykol 15%	Eth.glykol 15%	Eth.glykol 15%	Eth.glykol 15%	Eth.glykol 15%	CO2	CO2	Eth.glykol 15%
-3/-0.8	-2/+1.6	-3/-0.8	-3/+1.0	+6/+12.3	-3/+1.0	-/-	-/-	-/-	+7/+12
8.4	8.2	8.4	1.45	2.2	0.78	-	-	-	0.3

Teil / Komponente	P15-P18	P19-P22
Beschreibung	U-Pumpe	U-Pumpe
Fabrikat/Hersteller	Grundfos	Star-65-25-6
Typ	UPS-25-60	Star-65-25-6
Peff in kW	0.9	0.63
Medium K1	Eth.glykol 15%	Eth.glykol 15%
Volumenstrom	12	4

**Ausführungszeichnung**

**Globus Bingen**

Neubau  
Frischelager & Bäckerei  
Fließplan Luftkühler

Proj.-Nr.:

Copyright by EK-Moerssch GmbH